

# EC Declaration of Conformity

The undersigned of:

Honeywell Analytics Limited  
 4 Stinsford Road  
 Poole  
 Dorset  
 BH17 0RZ  
 United Kingdom

Declares that the product listed below:

## TOUCHPOINT 4

Touchpoint 4 controller provides protection of personnel and plant from flammable, toxic and oxygen gas hazards when used with up to four Sensepoint or Signalpoint gas detectors.

Self contained, fully user configurable and wall mounted, a Touchpoint 4 gas detection system can monitor gas hazards in a large area or several discrete locations from a convenient central site.

Conforms to the provisions of the following European Directive(s), when installed, operated, serviced and maintained in accordance with the installation/operating instructions contained in the product documentation:

2004/108/EC	EMC Directive
2006/95/EC	Low Voltage Directive

The standards and/or technical specifications referenced below have been applied or considered:

Harmonised Standard	Description
EN 50270:2006	Electromagnetic compatibility. Electrical apparatus for the detection and measurement of combustible gases, toxic gases or oxygen
EN 61010-1:2001	Safety requirements for electrical equipment for measurement, control and laboratory use. General requirements
<p><b>Attestation is provided for the Low Voltage Directive, based on the above standard requirements and the associated Technical File Number : TF-123104-2-TPWM 4</b></p>	

Year of CE Marking: 2004

Signature:



Name:

**Richard King**  
 Authorised Signatory

Date:

21<sup>st</sup> September 2012

Declaration Number:

2004Y0031\_02/A03835

Declaration of Conformity in accordance with EN ISO/IEC 17050-1:2010



INVESTOR IN PEOPLE